



Interim Legionella Positives Report for Job 1431686



Customer Reference: ABR test
Job Location: Torrington Avenue

TO: Name Of Company

DATE & TIME: 01 Sep 2017 13:58

Page 1 of 1

The sample(s) listed below have breached the predetermined limits for the analysis specified

Sample Number	Sample Description	Sampled On	Received On	Tested On	Sample Information	Analysis Name	Units	Result	Read Day	Comment
16369394	Shower 1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: Mess Room Client Address: CV4 9GU Site Ref: 12345	Legionella pneumophila Srg 1	cfu/litre	1		
16369394	Shower 1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: Mess Room Client Address: CV4 9GU Site Ref: 12345	Legionella pneumophila Srg2-15	cfu/litre	8		
16369394	Shower 1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: Mess Room Client Address: CV4 9GU Site Ref: 12345	Legionella Species	cfu/litre	53		

Please note that for Legionella samples, interim reads are performed. It is common for the final Legionella results to be higher than those reported at the interim reads, due to increased organism growth during the remaining incubation. All results contained in this report are provisional. If you need to query any of this data, please do not hesitate to contact your Customer Service Coordinator.

This message contains information only intended for the use of the company named above. It may also be confidential and / or privileged. If you are not the intended recipient of this message you are hereby notified that you must not disseminate, copy or take any action in reliance on it. If you have received this message in error please contact ALS Environmental at 024 7642 1213. The views expressed in this e-mail are not necessarily those of the company ALS Environmental.