

PCV Breach Report for Job 1431686

LOGO

Customer Reference: ABR test Job Location: Torrington Avenue

TO: Name Of Company

DATE & TIME: 01 Sep 2017 12:17

Page 1 of 1

The sample(s) listed below have breached the predetermined limits for the analysis specified

Sample Number	Sample Description	Sampled On	Received On	Tested On	Additional Sample Information	Analysis Name	Units	Result	Lower Limit	Upper Limit	Comment
16369112	Tap1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: First Floor Client Address: CV4 9GU Site Ref: 12345	Hydrogen ion (pH)	pH units	6.4	6.5	9.5	
16369112	Tap1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: First Floor Client Address: CV4 9GU Site Ref: 12345	Conductivity	uS/cm	2600		2500	
16369112	Tap1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: First Floor Client Address: CV4 9GU Site Ref: 12345	Turbidity	NTU	4.5		4.00	
16369112	Tap1	01/09/2017	01/09/2017	01/09/2017	Site: Torrington Avenue Location: First Floor Client Address: CV4 9GU Site Ref: 12345	Colour	mg/l Pt/Co	21		20	

All results contained in this report are provisional. If you need to query any of this data, please do not hesitate to contact your Customer Service Coordinator.